

**Noise Monitoring Data - Summary of Construction Noise Monitoring Results (30mins), dB(A)**

<b>NM1A - Slope near the Victoria Shanghai Academy</b>							
<b>Date</b>	<b>Time</b>		<b>Noise Levels, dB(A)</b>			<b>Wind Speed (ms-1)</b>	<b>Limit Level for L<sub>eq</sub> (30min/dB(A))</b>
	<b>Start</b>	<b>Finish</b>	<b>Corrected L<sub>eq</sub>(30min)<sup>(1)</sup></b>	<b>Corrected L<sub>90</sub><sup>(1)</sup></b>	<b>Corrected L<sub>10</sub><sup>(1)</sup></b>		
02-Jan-20	10:10	10:40	61.5	59.0	63.6	0.8	70
08-Jan-20	10:20	10:50	60.3	56.6	61.8	1.0	70
14-Jan-20	10:08	10:38	59.2	53.0	62.2	0.8	70
20-Jan-20	10:00	10:30	60.5	58.1	61.7	1.0	70
29-Jan-20	10:00	10:30	57.6	54.5	59.7	1.0	70

<b>NM2 - Hong Kong Juvenile Care Centre</b>							
<b>Date</b>	<b>Time</b>		<b>Noise Levels, dB(A)</b>			<b>Wind Speed (ms-1)</b>	<b>Limit Level for L<sub>eq</sub> (30min/dB(A))</b>
	<b>Start</b>	<b>Finish</b>	<b>L<sub>eq</sub>(30min)</b>	<b>L<sub>90</sub></b>	<b>L<sub>10</sub></b>		
02-Jan-20	09:20	09:50	51.0	48.9	52.2	0.8	70
08-Jan-20	09:20	09:50	51.7	48.2	53.1	0.8	70
14-Jan-20	09:25	09:55	52.1	50.1	54.0	1.0	70
20-Jan-20	09:20	09:50	51.5	48.8	52.9	1.0	70
29-Jan-20	09:20	09:50	47.3	42.1	50.1	1.0	70

(1) A free field correction of +3dB(A) has been made to these measurements as specified in the EM&A Manual and EPD guidelines.