

| NM1A - Slope near Victoria Shanghai Academy (VSA) | | | | | |
|--|--------------|---------------|--|----------------------------|----------------------------|
| Date | Time | | Construction Noise Monitoring Results (dB(A)) | | |
| | Start | Finish | *Correction Leq30min | *Correction L10 | *Correction L90 |
| 19-Jan-17 | 10:26 | 10:56 | 63.0 | 65.0 | 60.3 |
| 24-Jan-17 | 10:13 | 10:43 | 58.4 | 61.0 | 60.3 |
| 2-Feb-17 | 10:32 | 11:02 | 65.5 | 66.9 | 60.3 |
| 8-Feb-17 | 10:26 | 10:56 | 62.5 | 65.0 | 60.3 |
| 14-Feb-17 | 10:25 | 10:55 | 65.0 | 67.0 | 61.0 |

(*) A façade correction of +3dB(A) has been added according to acoustical principles and EPD guidelines

(#) Acceptable Noise Levels for school should be reduced to 65 dB(A) during examination period

| NM2 - Hong Kong Juvenile Care Centre (HKJCC) | | | | | |
|---|--------------|---------------|--|------------|------------|
| Date | Time | | Construction Noise Monitoring Results (dB(A)) | | |
| | Start | Finish | Leq30min | L10 | L90 |
| 19-Jan-17 | 9:37 | 10:07 | 58.0 | 61.0 | 54.5 |
| 24-Jan-17 | 9:21 | 9:51 | 57.9 | 59.5 | 48.0 |
| 2-Feb-17 | 9:32 | 10:02 | 61.2 | 63.6 | 59.0 |
| 8-Feb-17 | 9:21 | 9:51 | 58.7 | 61.5 | 54.0 |
| 14-Feb-17 | 9:32 | 10:02 | 59.0 | 61.0 | 55.0 |

(#) Acceptable Noise Levels for school should be reduced to 65 dB(A) during examination period