

**Noise Monitoring Data - Summary of Construction Noise Monitoring Results (30 mins), dB(A)**

<b>NM1A - Slope near the Victoria Shanghai Academy</b>						
<b>Date</b>	<b>Time</b>		<b>Noise Levels, dB(A)</b>			<b>Limit Level for Leq (dB(A))<sup>(2)</sup></b>
	<b>Start</b>	<b>Finish</b>	<b>Corrected Leq(30min)<sup>(1)</sup></b>	<b>Corrected L<sub>90</sub><sup>(1)</sup></b>	<b>Corrected L<sub>10</sub><sup>(1)</sup></b>	
06-Sep-17	10:00	10:30	61.6	58.4	63.0	70
13-Sep-17	10:10	10:40	62.1	58.9	63.7	70
20-Sep-17	09:24	09:54	60.9	57.7	62.1	70
27-Sep-17	11:00	11:30	63.9	56.0	65.5	70
04-Oct-17	09:40	10:10	63.7	58.9	67.1	70
10-Oct-17	13:50	14:20	60.4	57.9	62.7	70
18-Oct-17	10:00	10:30	60.2	55.3	63.8	70
26-Oct-17	09:40	10:10	60.3	58.5	62.2	70
01-Nov-17	09:02	09:32	61.2	59.3	62.2	70
07-Nov-17	09:35	10:05	60.6	58.4	62.3	70
15-Nov-17	10:10	10:40	59.1	57.0	61.1	70
23-Nov-17	10:35	11:05	60.0	54.8	63.8	70
29-Nov-17	10:00	10:30	59.2	55.3	61.3	70

<b>NM2 - Hong Kong Juvenile Care Centre</b>						
<b>Date</b>	<b>Time</b>		<b>Noise Levels, dB(A)</b>			<b>Limit Level for L<sub>eq</sub> (dB(A))<sup>(2)</sup></b>
	<b>Start</b>	<b>Finish</b>	<b>L<sub>eq</sub>(30min)</b>	<b>L<sub>90</sub></b>	<b>L<sub>10</sub></b>	
06-Sep-17	09:10	09:40	53.9	52.4	55.2	70
13-Sep-17	09:23	09:53	56.0	54.5	57.3	70
20-Sep-17	08:40	09:10	53.5	50.8	55.8	70
27-Sep-17	10:08	10:38	54.4	49.7	56.0	70
04-Oct-17	10:30	11:00	54.0	48.6	56.0	70
10-Oct-17	13:02	13:32	54.8	50.8	57.4	70
18-Oct-17	09:08	09:38	51.6	48.0	53.0	70
26-Oct-17	09:00	09:30	52.4	49.5	54.3	70
01-Nov-17	10:25	10:55	52.3	50.9	53.9	70
07-Nov-17	08:55	09:25	52.0	49.6	53.6	70
15-Nov-17	09:30	10:00	52.9	51.3	58.3	70
23-Nov-17	09:55	10:25	53.9	50.8	56.7	70
29-Nov-17	09:20	09:50	52.4	49.3	54.5	70

**Noise Monitoring Data - Summary of Construction Noise Monitoring Results (15mins), dB(A)**

<b>NM1A - Slope near the Victoria Shanghai Academy</b>						
<b>Date</b>	<b>Time</b>		<b>Noise Levels, dB(A)</b>			<b>Limit Level for L<sub>eq</sub> (dB(A))<sup>(2)</sup></b>
	<b>Start</b>	<b>Finish</b>	<b>Corrected L<sub>eq</sub>(5min)<sup>(1)</sup></b>	<b>Corrected L<sub>90</sub><sup>(1)</sup></b>	<b>Corrected L<sub>10</sub><sup>(1)</sup></b>	
26-Nov-17	15:35	15:50	55.0	50.3	57.7	70
			52.8	49.1	53.8	
			55.0	50.7	57.9	
<b>NM2 - Hong Kong Juvenile Care Centre</b>						
<b>Date</b>	<b>Time</b>		<b>Noise Levels, dB(A)</b>			<b>Limit Level for L<sub>eq</sub> (dB(A))<sup>(2)</sup></b>
	<b>Start</b>	<b>Finish</b>	<b>L<sub>eq</sub>(5min)</b>	<b>L<sub>90</sub></b>	<b>L<sub>10</sub></b>	
26-Nov-17	15:00	15:15	45.2	42.6	47.5	70
			45.3	41.2	41.2	
			44.2	42.0	42.0	

**Notes:**

- (1) A free field correction of +3dB(A) has been made to these measurements as specified in the EM&A Manual and EPD guidelines.
- (2) Acceptable noise level should be reduced to 65dB(A) upon school examination period.